



CSA INTERNATIONAL

# Certificate of Compliance

Certificate: 1005019 (113206)

Master Contract: 189893

Project: 1245439

Date Issued: October 25, 2001

Issued to: **Rinnai America Corporation**  
103 International Drive  
Peachtree City, Georgia 30269  
U.S.A.  
Attention: James A. Cika

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



Issued by: Robert Loria

Authorized by: George Gruss  
Operations Manager

## PRODUCTS

Class No: 2902-93  
COMMERCIAL HEATERS (GAS)  
Water Heaters

Model Number	Electric Rating	Maximum Input Rating	Minimum Input Rating	Storage Capacity	Altitude
For Use With Natural and Liquefied Petroleum Gases Instantaneous Water Heater					

Trade Name: RINNAI CONTINUUM

REU-2424W-US-(N,P)	180,000	19,000
REU-2424WC-US-(N,P)	180,000	19,000

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.



CSA INTERNATIONAL

Certificate: 1005019  
Project: 1245439

Master Contract: 189893  
Date: October 25, 2001

Class No: 2902-13  
COMMERCIAL HEATERS (GAS)  
Water Heaters

Model Number	Electric Rating	Maximum Input Rating	Minimum Input Rating	Altitude
--------------	-----------------	----------------------	----------------------	----------

For Use With Natural and Propane Gas  
Instantaneous Water Heater

Trade Name: RINNAI CONTINUUM

REU-2424W-US-(N,P)	B	180,000	19,000	N
	B	162,000	17,100	H
REU-2424WC-US-(N,P)	B	180,000	19,000	N
	B	162,000	17,100	H

**APPLICABLE REQUIREMENTS**

ANSI Z21.10.3-1998•CAN1-4.3-M98,  
ANSI Z21.10.3a-2000•CSA 4.3a-M00,  
ANSI Z21.10.3b-2000•CSA 4.3b-M00

Gas Water Heaters, Volume III  
Gas Fired Automatic Storage Type Water  
Heaters with Inputs above than 75,000 BTUH, Circulating and  
Instantaneous

**MARKINGS**

All markings and printed instructions are in compliance with the above mentioned requirements. Samples are contained in the main certification report.