Job Name/Location: Tag #: For: File Resubmit Date: Approval Other. PO No .: GC: Architect: Mech: Engr:

(Project Manager)



## LS090HEV

Mega Single Zone Inverter

Outdoor Unit (ODU) - LSU090HEV Indoor Unit (IDU) - LSN090HEV





#### Performance:

Cooling:

Rep: (Company)

Capacity (Btu/h)	8,500
SEER	16.3
EER	10.90

SEER - Seasonal Energy Efficiency Ratio EER - Energy Efficiency Ratio

Heating:

Capacity (Btu/h)	9,000
HSPF	8.3

HSPF - Heating Seasonal Performance Factor

Cooling Nominal Test Conditions: **Heating Nominal Test Conditions:** Indoor: 80°F DB/67°F WB Indoor: 70°F DB/60°F WB Outdoor: 95°F DB/75°F WB Outdoor: 47°F DB/43°F WB

#### **Electrical:**

Power Supply (V¹/Hz/Ø)	208-230/60/1
------------------------	--------------

#### **Outdoor Unit:**

MOP (A)	15
MCA (A)	9
Cooling Rated Amps (A)	7.3
Heating Rated Amps (A)	7.3
Compressor (A)	6.8
Fan Motor (A)	0.5

MOP - Maximum Overcurrent Protection MCA - Minimum Circuit Ampacity

## **Total Power Input:**

Cooling Power Input (kW)	0.78
Heating Power Input (kW)	0.78

#### Piping:

Liquid Line (in, OD)	1/4
Vapor Line (in, OD)	3/8
Additional Refrigerant (oz/ft)	0.22
Max Pipe Length (ft) <sup>2</sup>	49.2
Piping Length (no add'l refrigerant, ft)	24.6
Max Elevation (ft)	22.9

#### **Controls Features:**

•24-Hour on/off timer Energy saving

•2-Way (up/down) auto •Inverter (variable speed

swing compressor) Auto changeover Jet cool

•Self-cleaning indoor coil Auto restart

 Condensate sensor •Sleep mode

•Ultra quiet operation connection

### **Operating Range:**

**Outdoor Unit:** 

Cooling (°F DB)	64-118
Heating (°F DB)	23-75
Indoor Unit:	

Indoor Unit:

Cooling (°F DB)	64-90
Heating (°F DB)	60-86

#### **Unit Data:**

Refrigerant Type	R410A
Refrigerant Control	Capillary Tube
Refrigerant Charge (lbs)	1.66
ODU Sound Pressure (±3 dB(A)) <sup>3</sup>	47
IDU Sound Pressure ±3 (H/M/L/Sleep) dB(A) <sup>3</sup>	39/33/25/19
ODU Net Unit Weight (lbs)	52
ODU Shipping Weight (lbs)	56
IDU Net Unit Weight (lbs)	16
IDU Shipping Weight (lbs)	21
Heat Exchanger Coating	GoldFin™

## Fan:

ODU Type	Propeller
IDU Type	Cross Flow
Fan Speeds (Fan/Cooling/Heat	ing) 4/4/4
Quantity (ODU + IDU)	1+1
Motor/Drive Bro	ushless Digitally Controlled/Direct
ODU Max Air Flow Rate (CFM)	953
IDU Air Flow Rate H/M/L (CFM	) 276/226/177
Dehumidification (pts/hr)	2.12

## Notes:

- 1.Acceptable operating voltage: 187V-253V.
- 2. Piping lengths are equivalent.
- 3. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 1996.
- 4.All power/communication cable to be minimum 18 AWG, 4-conductor, stranded, shielded
- and must comply with applicable local and national code. 5.See Engineering Manual for sensible and latent capacities
- 6. Power wiring cable size must comply with the applicable local and national code.
- 7.The indoor unit comes with a dry helium charge. 8.This data is rated 0 ft above sea level, with 24.6 ft of refrigerant line and a 0 ft level difference between outdoor and indoor units.
- 9. Must follow installation instructions in the applicable LG installation manual.





# Outdoor Unit (ODU) - LSU090HEV


Mega Single Zone Inverter





Life's Good PO No.:

Tag #:

Date:









ltem No.	Part Name	Remarks
1	Return Air Grille	
2	Gas Pipe Connection Port	
3	Liquid Pipe Connection Port	
4	Control Box	
5	Earth Screw	


## Indoor Unit (IDU) - LSN090HEV Mega Single Zone Inverter



	Tag #:			
	Date:			
ı				







5	4	3	2	1	Item No.	
Installation Plate	Knockout hole	Return Air Grille	Display & Signal Receiver	Front Panel	Part Name	
	For pipe and cable				Remarks	